Tishman Realty & Construction Co. Inc.

K-27

To: Mr. F. Wernecke, P/A

From: Mr. M. Gerstman, TRCC 6/25/69

Subject: WTC 113.00 - Spray-on Fireproofing

We have submitted, for approval, the following spray-on fireproofing samples in behalf of Mario & DiBono:

1. Cafco Blaze Shield Type D

2. Cafco Blaze Shield Type D with Mark II Coating (overspray)

We have received from E. Roth approval of Item #1 but Item #2 has been disapproved with the remark - "Spec. calls for Mark III".

There is a definite discrepancy in the specification. On Page 122, para. 13.01, a, 4, the specification calls for applying CAFCO Mark II Hard Finish. On Page 127, para. 13.09, 2, b, the specification calls for sample panels with CAFCO Mark III over spray.

Please advise which coating is required.

DM/MG/eb

cc-R. Monti, P/A

cc-J. Solomon (Emery Roth)

Note: United States Mineral Products Company advises that there is no such thing as a Mark III coating. This must be a typographical error.

THE PORT OF NEW YORK AUTHORITY
OFFICE OF CONSTRUCTION MANAGER
RECEIVED
JUN 30 1969
PLANNING & CONSTRUCTION DIVISION

PLAINTIFF'S EXHIBIT
PX-516